



Certificate of compliance Subsystem



Holder BHDT, Kapfenberg, Austria

Compliant Item(s) See next page

Basis of Certification IEC 61508:2010
IEC 61511:2016

Certification Include(s)

- ☒ Management of functional safety
- ☒ Safety requirements specification
- ☒ Hardware requirements
- ☒ Reliability requirements
- ☒ Basic safety
- ☒ User documentation

Functional Safety Data

Safety function: Upon demand close valve
Functional safety parameters: See next page

Certification Results Risknowlogy certifies that the above Compliant Item(s) meets the requirements of the Basis of Certification for the selected assessment(s). The Risknowlogy report 2628.574.13 are an integral part of this certificate.

Certificate Number 2628.574.14-0

Initial Certification 2023-10-19

This Certificate 2023-10-19

Expiry Date 2028-10-19

Certifier Dr. Michel Houtermans





Certificate of compliance Subsystem



Group	Subsystem	Type	S D	SU	DD	DU	SFF	HFT=0	HFT=1
1	3232UZV-12129	A	0	2	0	85	2.0%	SIL 1	SIL 2
2	3233UZV-06005, 3233UZV-06006, 3233UZV-06007, 3233UZV-06008, 3233UZV-06009, 3233UZV-06010, 3233UZV-06011, 3233UZV-06012	A	0	2	0	85	2.0%	SIL 1	SIL 2
3	3232UZV-12106	A	0	2	0	85	2.0%	SIL 1	SIL 2
4	3232UZV-12105	A	0	3678	0	14792	19.9%	SIL 1	SIL 1
5	3232UZV-12007	A	0	3678	0	14792	19.9%	SIL 1	SIL 1
6	3232UZV-15015	A	0	3678	0	14792	19.9%	SIL 1	SIL 1
7	3232UZV-14003	A	0	3678	0	14792	19.9%	SIL 1	SIL 1

