

## Certificate of compliance

## **Product**



Holder BHDT, Kapfenberg, Austria

Compliant Item(s) 1220979

Basis of Certification IEC 61508:2010

**Certification Include(s)** ✓ Management of functional safety

☑ Safety requirements specification

☑ Hardware requirements☑ Reliability requirements

☑ Basic safety

☑ User documentation

## **Functional Safety Data**

Safety function: See report

Mode: Low demand

Type: A HFT: 0

Hardware compliance route: 1<sub>H</sub>
Systematic compliance route: 1<sub>S</sub>
Systematic capability: SC2

Failure rates (FIT): SD=0, SU=0, DD=0, DU=81, NE=154, NP=0

Safe failure fraction: 0%

Fit for use up to: SIL 1 in HFT=0 and SIL 2 on HFT=1

**Certification Results** Risknowlogy certifies that the above Compliant Item(s)

meets the requirements of the Basis of Certification for the selected assessment(s). The Risknowlogy report

2628.573.13 is an integral part of this certificate.

Certificate Number 2628.573.6-0

Initial Certification 2023-10-13

This Certificate 2023-10-13

**Expiry Date** 2028-10-13

**Certifier** Dr. Michel Houtermans



