

# Certificate of Compliance

## Safety Instrumented System

**Holder:** HIMA France, Paris, France

**Safety Instrumented System:** HIPPS Logic Solver

**Location(s):** TUNU Field - NMP3

**Basis of audit:** IEC 61511:2003

**Assessment include(s):**

- ☒ Safety requirements specification
- ☒ Hardware requirements
- ☒ Reliability requirements
- ☒ Logic requirements
- ☒ Factory acceptance testing

**Functional Safety Data:**

|                 |            |
|-----------------|------------|
| SIF Identifier  | HIPPS      |
| Safety function | See report |
| Mode            | Low demand |
| SIL             | 4          |

**Audit results:**

Risknowlogy certifies that the above Safety Instrumented System meets the requirements of the Basis of Testing for the selected assessment(s). The Risknowlogy report 151.103.1 and safety manual are an integral part of this certificate.

**Certificate number:** 4592.103.2

**Issue date:** 2009-03-30

**Expiration date:** After modification of Safety Instrumented System

**Certifier:**